

RFP #384 – Questions & Answers Addendum #3

- 1. Please specify as concretely as possible where the perimeter of JIA ends and where that of the provider starts. More concretely regarding: concrete pad, electric panel, breakers, wiring.**

A: JIA's responsibility ends at the electrical panel.

- 2. What is the maximum distance between the electrical panel and the individual chargers at each location that we should use for the estimate?**

A: Approximately 100'. See site photos for reference.

- 3. Please confirm the power capacity of the electric panel in each site as well as the breaker size allocated to each individual charger in every site.**

A: Minimum of 50 amps.

- 4. Will the available power need to be distributed among the proposed chargers? Which one of the sites are you expecting power sharing?**

A: Chargers will have a dedicated panel or sub-panel.

- 5. Is there any historical data available on charger demand or usage in the different locations?**

A: No.

- 6. Would it be possible to consider a phased installation approach based on demand?**

For example, installing half of the chargers initially and adding the remaining units as demand increases, always granting sufficient capacity for the current demand.

A: Units installed will be as listed in Q&A #3 in Addendum #2.